

MODEL 4152

KILLSWITCH



- **A SAFE AND CONVENIENT WAY TO DIS-CONNECT PANEL POWER**
- **REMOVES POWER FROM BACK-UP BATTERY AND A/C SOURCE**
- **D.P.S.T. SWITCH WITH 10 AMP. CONTACTS**
- **UNIQUE CLIP ALLOWS QUICK AND EASY INSTALLATION**
- **MOUNTS IN ANY SECURITY CABINET**



ALARM CONTROLS CORPORATION
19 BRANDYWINE DRIVE DEER PARK, NY 11729

1 631 586-4220 1 800 645-5538

WWW.ALARMCONTROLS.COM EMAIL INFO@ALARMCONTROLS.COM

INSTALLATION INSTRUCTIONS

4152 KILLSWITCH

MAKE SURE KILLSWITCH IS IN THE "OFF" POSITION BEFORE INSTALLING

- _1. CLIP KILLSWITCH ASSEMBLY TO SIDE OF CONTROL PANEL CABINET.**
- 2. REMOVE POSITIVE LEAD FROM BATTERY AND CONTROL PANEL AND DISCARD.**
- 3. CONNECT *RED LEAD* WITHOUT FASTON TERMINAL TO CONTROL PANEL *POSITIVE* TERMINAL.**
- 4. CONNECT *RED LEAD* WITH FASTON TERMINAL TO *POSITIVE* BATTERY TERMINAL.**
- 5. REMOVE ONE SIDE OF A/C TRANSFORMER LEAD AND CONNECT *BROWN LEAD* FROM KILLSWITCH**
- 6. CONNECT OTHER *BROWN LEAD* FROM KILLSWITCH TO CONTROL PANEL A/C TERMINAL.**
- 7. PLACE KILLSWITCH IN "ON" POSITION.**



ALARM CONTROLS CORPORATION

DEER PARK, NY 11729