



FOR TRADITIONAL MOUNTING INSTALLATIONS

- Measure the depth from the back of the stile to the inside wall of door edge (Fig. 1).
- Match the distance from the face of the Mounting Plate to the end of Tube Spacer. Use 3/16" Hex Key for fine adjustment (Fig. 2).




FOR MOUNTING TAB INSTALLATIONS


- Remove top and bottom #8-32 x 5/16" Truss Head Screw as shown (Fig. 3).
- Remove Yoke, and refasten #8-32 x 5/16" Truss Head Screw (Fig. 4).



BEVEL ADJUSTMENT


- Rotate Bevel Tab to desired hand (Fig. 5). Using the bevel adjustment allows the Flat Faceplate to work in beveled stiles. Radius and Flat Faceplates are included.






RHR BEVEL POSITION

Fig. 5



FOR RADIUS WITH WEATHERSEAL FACEPLATE ONLY


With a small screwdriver, remove bevel tabs as shown (Fig. 6).




SOLENOID SPECIFICATION

SOLENOID AVAILABLE VOLTAGES 12V DC CONTINUOUS DUTY, 24V DC CONTINUOUS DUTY.


SOLENOID WIRING DIAGRAM





4300 WIRING DIAGRAM

VOLTAGE ADAPTOR CABLE			
P/N#	WIRE COLOR	IAPPI ICATION	SOLENOID
			CURRENT DRAW
31-0360-01	BLACK	12V DC	0.44 AMPS
31-0360-02	RED	24V DC	0.24 AMPS



- EXTEND THE WIRE RUN FROM THE POWER SOURCE AND THROUGH THE STILE PREPARATION. CONNECT THE WIRE TO THE VOLTAGE ADAPTOR CABLE.
- ATTACH VOLTAGE ADAPTOR CABLE TO 4300 AS SHOWN.

ECN: 11847


MONITORING (OPTIONAL)

MONITORED DEADLATCH CONTAINS AN INTERNALLY MOUNTED SWITCH. THIS SWITCH IS ACTIVATED WHEN THE DOOR IS IN CLOSE POSITION. ALL UNUSED LEADS FROM THE MONITOR SWITCH MUST BE INSULATED.

Common contact - Black Normally Open contact (N.O.) - White Normally Closed contact (N.C.) - Red

Maximum switching current - 0.1 Amps @ 125 VAC

EXAMPLE WIRING DIAGRAM WITH N.O. MONITORING



Black = Common White = N.O. contact (Dry) Red = N.C. contact (Dry) Unused wires must be cut such that no exposed wire will touch any metallic surface

Adams Rite Manufacturing Co. 260 Santa Fe Street, Pomona, CA 91767

ASSA ABLOY

Phone: 909-632-2300 Fax: 909-632-2369

4300 SERIES ELECTRIFIED DEADLATCH

80-0180-421 Rev. C

PRODUCT MUST BE INSTALLED **ACCORDING TO ALL APPLICABLE BUILDING AND LIFE SAFETY CODES** **INSTALLATION INSTRUCTIONS**

Page 2 of 2 Appvd: MP Date: 10/20/11