

# **SPECIFICATIONS**

### WIRING INFORMATION






#### **DYNALOCK MODEL #6901 PUSHPLATE FEATURES:**

DOUBLE GANG RED ANODIZED ALUMINUM PUSHPLATE WITH "PUSH TO EXIT" ENGRAVED SIGNAGE: WHITE, 1" HEIGHT, 1/8" STROKE

2-60 SECOND TIME DELAYED MOMENTARY CONTACTS

7" COLOR-CODED #18AWG WIRE LEAD TERMINATIONS


# **SCHEMATIC**



RATED 10 AMPS @ 120VAC PTD / FORM Z

#### TIME DELAY ADJUSTMENT

TIME DELAY ADJUSTMENT KNOB



TURN CW TO INCREASE TURN CCW TO DECREASE

TIME DELAY ADJUSTMENT RANGE = 2 - 60 SECONDS



DynaLock Corporation 705 Emmett Street • Bristol, CT 06010 Tel: (860) 582-4761 • Fax: (860) 585-0338 Installation Instructions

DRWN:	Date:	
M	IJL 10/29/0	7
CHK'D:	Date:	
CHK'D:	Date:	
APPV'D:	Date:	
	CHK'D:	MJL 10/29/0 CHK'D: Date:  CHK'D: Date:


6901 PUSHPLATE, DOUBLE GANG


Page 1 Of 1

Size: Drawing #: 600351

# **SPECIFICATIONS**

## WIRING INFORMATION





#### DYNALOCK MODEL #6911 / 6921 PUSHPLATE FEATURES:


DOUBLE GANG RED ANODIZED ALUMINUM PUSHPLATE WITH "PUSH TO EXIT" ENGRAVED SIGNAGE: WHITE, 1" HEIGHT, 1/8" STROKE

7" COLOR-CODED #18AWG WIRE LEAD TERMINATIONS.

6911 - SPDT / ALTERNATE ACTION CONTACTS, RATED 6 AMPS @ 125VAC

6921 - DPDT / ALTERNATE-ACTION CONTACTS, RATED 6 AMPS @ 125VAC

# BLACK (C) (NC) YELLOW O(NO) GRAY O(NO) SPDT ALTERNATE-ACTION CONTACTS RATED 6 AMPS @ 125VAC





DynaLock Corporation 705 Emmett Street • Bristol, CT 06010 Tel: (860) 582-4761 • Fax: (860) 585-0338 Installation Instructions


	DRWN:	MJL	Date: 10/29/07
;	CHK'D:		Date:
	CHK'D:		Date:
	APPV'D	):	Date:
_			


6911 / 6921 PUSHPLATE DOUBLE GANG


					_
age	Scale:	Size:	Drawing #:		RE
1 Of 1		Α		600352	-

# **SPECIFICATIONS**

# WIRING INFORMATION







# MODEL #6941 (DPDT) C O NC O NC C O NC O NC

#### **DYNALOCK MODEL #6931 / 6941 PUSHPLATE FEATURES:**

DOUBLE GANG RED ANODIZED ALUMINUM PUSHPLATE WITH "PUSH TO EXIT" ENGRAVED SIGNAGE: WHITE, 1" HEIGHT, 1/8" STROKE

LABELED SCREW TERMINAL CONNECTIONS

6931 - SPDT / MOMENTARY CONTACTS, RATED 15 AMPS @ 125VAC 6941 - DPDT / MOMENTARY CONTACTS, RATED 10 AMPS @ 125VAC

DynaLock

DynaLock Corporation 705 Emmett Street • Bristol, CT 06010 Tel: (860) 582-4761 • Fax: (860) 585-0338 Installation Instructions

	DRWN:		Date:	
		MJL	06/09/08	
,	CHK'D:	JAS	Date: 06/10/08	
	CHK'D:		Date:	
	APPV'D	):	Date:	

6931 / 6941 PUSHPLATE
DOUBLE GANG

Page	Scale:	Size:	Drawing #:	00005
1 Of 1	_	A		60035