

INSTALLATION INSTRUCTIONS K-129 AUTHORIZED EGRESS (AE) SWITCH KIT

FOR USE WITH FALCON 24 AND 25 SERIES EXIT DEVICES

Electrical Specifications:

Wire Leads: 22AWG
SPDT Monitor Switch:
Contact Rating: 3A @ 125VAC
2A @ 30VDC

Wire Color Codes:

Yellow Wire: Common
Red Wire: Normally Open
Gray Wire: Normally Closed

Installation:

1. Separate the channel from the pushbar assembly.
2. Remove the rear pin securing the pushbar assembly to the sub-plate and elevate the rear of the pushbar assembly.
3. Locate the K-129 Kit between the sub-plate and the pushbar assembly.
4. Lower the pushbar assembly back into position and replace the rear pin to secure the pushbar assembly to the sub-plate. Verify the tabs of the pushbar assembly linkage are between the tabs of the switch bracket.
5. Route the lead wires along the outside edge of the pushbar assembly.
6. Attach the channel to the pushbar assembly.
7. Secure the lead wires to the inside of the channel using the supplied ty-wrap mount and ty-wrap.

SWITCH MONITORS PUSHBAR DEPRESSION

